

FIELD TERMINATION PLUG USER GUIDE

1

COPPER FOIL TAPE
30MM
10MM

SR-A Ø9.0
OR
SR-B Ø7.3

2

BOOT
CABLE

3

30MM MIN.
10MM
OR
30MM MIN.
10MM
S/FTP U/FTP.F/UTP

4

30MM MIN.
10MM
COPPER FOIL TAPE

5

30mm Min.
10mm
WRAPPED UP

6

7/8 4/5 3/6 1/2
7/8 4/5 3/6 1/2
7/8 4/5 3/6 1/2
7/8 4/5 3/6 1/2

7

8

5-8MM MAX.

9

10 CUT FRONT ROW WIRES FLUSH

CUT 2
CUT 1
0.2MM MAX.

11

12a

2
CLICK
3

12b OPTIONAL ETC(EASY TOOL TO CRIMP) TOOL

3
1
2

13

OK NG

14

15

LEGEND
W WHITE
G GREEN
O ORANGE
BL BLUE
BR BROWN

1	2	3	4	5	6	7	8
W-G	G	W-O	BL	W-BL	O	W-BR	BR

PIN ASSIGNMENT T568A

1	2	3	4	5	6	7	8
W-O	O	W-G	BL	W-BL	G	W-BR	BR

PIN ASSIGNMENT T568B

CABLE INFORMATION FOR INSTALLATION				
	TYPE	CONDUCTORS	WIRE OD(MM)	CABLE OD(MM)
C6A	23-26AWG	STRANDED & SOLID	1.0-1.4	6.0-8.5
C6A	22-24AWG		1.2-1.5	
C8	22-24AWG		1.2-1.7	